

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-1328:111 Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: Air Balance, Inc., 7301 International Drive, Holland, OH 43528
Contact: Chuck Schneider (419) 865-5000 *FAX (419) 865-1375

DESIGN: Models SA1 250, SA1 350, SA2 250 and SA2 350 leakage dampers. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For **vertical** mount only.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as Class I (Models SA1 250 and SA1 350) or Class II (Models SA2 250 and SA2 350) leakage-rated dampers.

*Rev. 06-08-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**